

**Construction Products Regulation  
Declaration of Performance (DoP)**

According to Annex III of the Regulation (EU) No 305/2011



**DoP No. FIRETRAK115CPR1908022**

From 1 July 2013, CE Marking of Construction Products covered by harmonised European Standards is mandatory.

Rutland UK are widely known for the manufacture of designer door closers that last, committed to fulfil and exceed standards to ensure the safety of the user.

---

**1. Unique identification code of the product/type:**

TS.FIRETRAK.115 Electromagnetic slide rail and connector bar hold open device for swing doors.

**2. Re-order Code allowing identification of the construction product as required under Article 11(4) of CPR:**

TS.FIRETRAK.115.SE order code 12448, TS.FIRETRAK.115.SNP order code 12449

**3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:**

For self closing requirements of fire and smoke compartmentation doors, when fitted and maintained in accordance with the manufacturers instructions.

**4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11 (5):**

Rutland UK, Whittington Way, Chesterfield, S41 9AG, UK

**5. Where applicable. Name and contact address of authorised representative whose mandate covers the tasks specified in Article 12(2):**

N/A

**6. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:**

System 1

**7. In case of the declaration of performance concerning a construction product covered by a harmonized standard:**

EN 1155:1997+A1:2002/AC:2006

**8.1 Notified body**

IFCC, Park Street Business Centre, 20 Park Street, Princes Risborough, HP27 9AH  
Notified body No. 1720

**8.2 ID Certificate**

1720-CPR-0213

## 9. Declared performance

### Conditioning:

- Power size 2-5 in regular Pull-side standard fixing application, with adjustable closing and latch action. Maximum hold open angle 130 degrees.

Essential Characteristics	Performance	Harmonised Technical Specification
<i>Self-closing (5.2.1 General)</i>		EN 1155:1997+A1:2002/AC:2006
5.1.2 Release from any angle	Pass	
5.1.3 Not possible to inhibit the release	Pass	
5.1.4 Supply voltage	Pass	
5.1.5 External electrical connection	Pass	
5.1.6 Inlet for external wiring	Pass	
5.2.1 General	Pass	
5.2.2 Electrical release	Pass	
5.2.3 Door closing device requirements	BS EN 1154 Pass	
5.2.4 Durability	Pass	
5.2.5 Angle of hold open	Pass	
5.2.6 Manual release	Pass	
5.2.7 Continuous hold open	Pass	
5.2.8 Overload performance	Pass	
5.2.9 Delayed release	NA	
5.2.10 Electrical performance	Pass	
5.2.11 Temperature rise	Pass	
5.2.12 Damage	Pass	
5.2.13 Fire/Smoke doors	Pass	
Durability of Ability to release	Pass Grade 2	
5.2.14.1 Corrosion		
5.2.14.2 Corrosion		
Hazardous Substances Annex ZA3	Pass: No hazardous substances in terms of the EC guidelines and REACH directive	EN 1155:1997+A1:2002/AC:2006

- 10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9. This Declaration of Performance is issued under the sole responsibility of the manufacturer identified in point 4.**

Signed for an behalf of the manufacturer:



---

Neil Smith (Technical Manager)

**Place and date of issue**

Chesterfield, UK. 02.08.2019.

