

CERTIFICATE OF CONSTANCY OF PERFORMANCE

1720-CPR-0205

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR)*, this certificate applies to the construction product:

TS.FireTrak ***Electromagnetic slide rail and connector bar***

a surface mounted Electromagnetic slide rail and arm for use on fire resisting and smoke control doors, single and double leaf doors.

Particular conditions applicable: **Only permitted for use with *TS.11204 EN2-4 door closer and **TS.11205 EN 2-5 door closer.**

product classification

3	8	2 4 *	1	1	3
---	---	----------	---	---	---

3	8	2 5 **	1	1	3
---	---	-----------	---	---	---

produced by

Rutland UK

Whittington Way, Chesterfield, S41 9AG

and produced in the manufacturing plant(s)

Factory Code: B - Q

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 1155:1997 + A1:2002

Under system 1 are applied and that the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 29th March 2019. It will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.




Director of Certification

Place of issue: Princes Risborough, UK

IFC Certification Ltd

Notified Body No. 1720

20 Park Street, Princes Risborough, Buckinghamshire, HP27 9AH, UK
Tel: +44(0) 1844 275500, Fax: +44(0) 1844 274002, E-mail: info@ifccertification.com

Registered No: 4777898 England

©IFC Certification Ltd 2014