

# DECLARATION OF PERFORMANCE



## DoP-Firetrak.115-EM-UKCA



### (TS.Firetrak.115)

- Unique identification code of the product / type:-
- **TS.Firetrak.115 2-5 variable power Surface Fixed Electro-magnetic Slide Arm Door Closer with adjustable latch action, 130 degree maximum opening angle. Fitted as Standard or Transom fitting.**
- **Re-order Code allowing identification of the construction product as required under Article 11(4) of CPR:** 12448, 12449
- Intended use:- For use on fire/smoke compartmentation doors, when fitted in accordance with the supplied fitting instructions and maintained to the manufacturers O&M Manual.
- Manufacturer:- Rutland UK, Unit 4, Holmewood Business Park, Chesterfield Road, Chesterfield, S42 5US, UK
- System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V :- System 1
- Harmonised Standard:- BS EN 1155:1997 + A1:2002
- Notified Body:- IFCC Conformity Assessment body No. 1720
- Certification No.:- 1720-CPR-0230
- Declared Performance:-

Conditioning: Standard Position (Fig 1) power size 2-5, and adjustable latch action, 130 degree maximum opening angle.

Essential Characteristics	Performance	Harmonised Technical Specification
<i>Ability to release</i>		BS EN 1155:1997 + A1:2002
5.1.2 Release from any angle	Pass	
5.1.3 Not possible to inhibit the release	Pass	
5.1.4 Supply voltage	Pass	
5.1.5 External electrical contact	Pass	
<i>General</i>		
5.2.2 Electrical release	Yes	
5.2.3 Door closing device EN1154 requirements	Yes	
5.2.4. Durability	Pass	
5.2.5 Angle of hold open	Pass	
5.2.6 Manual release	Pass	
5.2.7 Continuous hold open	Pass	
5.2.8 Overload performance	Pass	
5.2.9 Delayed release	Pass	

# DECLARATION OF PERFORMANCE



5.2.10 Electrical Performance	Pass
5.1.11 Temperature Rise	Pass
5.1.12 Damage	No
5.1.13 Fire / smoke doors	Yes

<i>Durability of ability to release</i>		BS EN 1155:1997 + A1:2002
5.2.14.2 Corrosion resistance	High corrosion resistance - Grade 3 (96 hours)	
Dangerous Substances	Pass: the materials in the door closer do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations	

The performance of the product identified above is in conformity with the set of declared performance/s.

This declaration of performance is issued, in accordance with the Construction Products (Amendment etc) (EU Exit) Regulations, 2019 No. 465 & 2020 No.1359.

Signed for and on behalf of the manufacturer by:

A handwritten signature in black ink, appearing to read 'Kevin O'Reilly', written over a horizontal line.

Kevin O'Reilly  
Technical Director

Dated 18-04-2024