## DECLARATION OF PERFORMANCE

## DoP-TS.4204-66-UKCA

## (TS.4204 Fig 66)

- Unique identification code of the product / type: TS.4204 DA BC 2-4 variable power Surface Fixed Door Closer with Fig 66 Parallel Arm Fixing Position, with adjustable latch action, 120 degree maximum opening angle.
- Re-order Code allowing identification of the construction product as required under Article 11(4) of CPR: 12495, 12496
- Intended use:- For use on fire/smoke compartmentation doors, when fitted in accordance with the supplied fitting instructions and maintained to the manufacturers O&M Manual.
- Manufacturer:- Rutland UK, Unit 4, Holmewood Business Park, Chesterfield Road, Chesterfield, S42 5US, UK
- System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V :- System 1
- Harmonised Standard:- BS EN 1154:1997 + A1:2002
- Notified Body:- IFCC UK Conformity Assessment body No. 1720
- Certification No.:- 1720-CPR-0180
- Declared Performance:-

Conditioning: Parallel Fixed Arm Position (Fig 66) power size 2-4, with adjustable latch action, 120 degree maximum opening angle

| Essential Characteristics       | Performance                                | Harmonised<br>Technical<br>Specification |
|---------------------------------|--|--|
| Self-closing (5.2.1 General)    |  |  |
| 5.2.2 Durability                | 500,000 test cycles                        |  |
| 5.2.3 Closing moment            | Power size 2 - 4                           |  |
| 5.2.4 Opening moment            | Power size 2 - 4                           |  |
| 5.2.5 Efficiency                | Pass                                       |  |
| 5.2.6 Closing time              | Pass                                       |  |
| 5.2.7 Angles of operation       | Grade 3 for closing doors from 105 degrees | BS EN 1154:1997 +                        |
| 5.2.8 Overload performance      | Pass                                       | A1:2002                                  |
| 5.2.9 Temperature dependence    | -15°C to +40°C                             |  |
| 5.2.10 Fluid leakage            | Pass                                       |  |
| 5.2.11 Damage                   | Pass                                       |  |
| 5.2.12 Latch control            | Pass                                       |  |
| 5.2.13 Back check               | Pass                                       |  |
| 5.2.15 Adjustable closing force | Pass                                       |  |



## DECLARATION OF PERFORMANCE



| Durability of Self Closing  |  |                   |
|-----------------------------|--|-------------------|
| 5.2.2 Durability            | 500,000 test cycles – Grade 8  | BS EN 1154:1997 + |
| 5.2.17 Corrosion resistance | High corrosion resistance - Grade 3 (96 hours)   |                   |
| Dangerous Substances        | Pass: the materials in the door closer do not contain<br>or release any dangerous substances in excess of the<br>maximum levels specified in existing European<br>material standards or any national regulations (1) | A1:2002           |

The performance of the product identified above is in conformity with the set of declared performance/s.

This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

10 Kelly

Kevin O'Reilly Technical Director

Dated 18-04-2024