

DECLARATION OF PERFORMANCE



DoP-TS.9206-1/66-CE

(TS.9206 Fig 1 Pull Side & Fig 66 Push Side)

- Unique identification code of the product / type:-
TS.9206 DA BC 3-5 variable power Surface Fixed Door Closer with Fig 66 Parallel Arm Fixing Position, with optional back check, delayed action and adjustable latch action, 120 degree maximum opening angle.
TS. 9206 DA BC 3-5 variable power Surface Fixed Door Closer with Fig 1 Standard Fixing fitted pull side with optional back check, delayed action and adjustable latch action, 180 degree maximum opening angle.
- **Re-order Code allowing identification of the construction product as required under Article 11(4) of CPR:**
 11797, 11806, 11807, 11800, 11802, 11809, 11801, 11931, 12116, 11604, 11799
- Intended use:- For use on fire/smoke compartmentation doors, when fitted in accordance with the supplied fitting instructions and maintained to the manufacturers O&M Manual.
- Manufacturer:- Rutland Door Controls Europe Limited, Unit 5B, Fingal Bay Business Park, Balbriggan, Dublin, Ireland
- System/s assessment and verification of constancy of performance (AVCP):- System 1
- Harmonised Standard:- EN 1154:1996 + A1:2002
- Notified Body:- Efectis EU notified body no. 1812
- Certification No.:- 1812-CPR-1890 dated 08-01-2024
- Declared Performance:-

Conditioning: Parallel Arm Fixing Position (Fig 66) power size 3-5, with optional back check, delayed action and adjustable latch action, 120 degree maximum opening angle

Essential Characteristics	Performance	Harmonised Technical Specification
<i>Self-closing (5.2.1 General)</i>		EN 1154:1996 + A1:2002
5.2.2 Durability	500,000 test cycles	
5.2.3 Closing moment	Power size 3 - 5	
5.2.4 Opening moment	Power size 3 - 5	
5.2.5 Efficiency	Pass	
5.2.6 Closing time	Pass	
5.2.7 Angles of operation	Grade 3 for closing doors from 105 degrees	
5.2.8 Overload performance	Pass	
5.2.9 Temperature dependence	-15°C to +40°C	
5.2.10 Fluid leakage	Pass	
5.2.11 Damage	Pass	
5.2.12 Latch control	Pass	
5.2.13 Back check	Pass	
5.2.15 Adjustable closing force	Pass	

DECLARATION OF PERFORMANCE



<i>Durability of Self Closing</i>		EN 1154:1996 + A1:2002
5.2.2 Durability	500,000 test cycles – Grade 8	
5.2.17 Corrosion resistance	High corrosion resistance - Grade 3 (96 hours)	
Dangerous Substances	Pass: the materials in the door closer do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations (1)	

The performance of the product identified above is in conformity with the set of declared performance/s.

This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

A handwritten signature in black ink, appearing to read 'Kevin O'Reilly', written over a horizontal line.

Kevin O'Reilly
Technical Director

Dated 18-04-2024