

DECLARATION OF PERFORMANCE



DoP-Responder.24-EM-CE



(Responder 24 Fig 1 & Fig 61)

- Unique identification code of the product / type:-
Responder 24 2-4 variable power Surface Fixed Electro-magnetic Door Closer with Fig 1 Standard Fixing Position, with hold open, swing free and adjustable latch action, 150 degree maximum opening angle. Fig 61 Transom mounting with min 20mm head projection
- **Re-order Code allowing identification of the construction product as required under Article 11(4) of CPR:**
10912, 19913, 10910, 10909, 12193, 12409
- Intended use:- For use on fire/smoke compartmentation doors, when fitted in accordance with the supplied fitting instructions and maintained to the manufacturers O&M Manual.
- Manufacturer:- Rutland Door Controls Europe Limited, Unit 5B, Fingal Bay Business Park, Balbriggan, Dublin, Ireland
- System/s assessment and verification of constancy of performance (AVCP):- System 1
- Harmonised Standard:- EN 1155:1997 + A1:2002
- Notified Body:- CEM International EU notified body no. 1942
- Certification No.:- 1942-CPR-44-01111-18-01
- Declared Performance:-

Conditioning: Standard Position (Fig 1) power size 2-4, with hold open, swing free, 150 degree maximum opening angle

Essential Characteristics	Performance	Harmonised Technical Specification
<i>Ability to release</i>		EN 1155:1997 + A1:2002
5.1.2 Release from any angle	Pass	
5.1.3 Not possible to inhibit the release	Pass	
5.1.4 Supply voltage	Pass	
5.1.5 External electrical contact	Pass	
<i>General</i>		
5.2.2 Electrical release	Yes	
5.2.3 Door closing device EN1154 requirements	Yes	
5.2.4. Durability	Pass	
5.2.5 Angle of hold open	Pass	
5.2.6 Manual release	Pass	
5.2.7 Continuous hold open	Pass	
5.2.8 Overload performance	Pass	

DECLARATION OF PERFORMANCE



5.2.9 Delayed release	Pass
5.2.10 Electrical Performance	Pass
5.1.11 Temperature Rise	Pass
5.1.12 Damage	No
5.1.13 Fire / smoke doors	Yes
5.2.9 Delayed release	Pass

<i>Durability of Self Closing</i>		EN 1155:1997 + A1:2002
5.2.17 Corrosion resistance	High corrosion resistance - Grade 3 (96 hours)	
Dangerous Substances	Pass: the materials in the door closer do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations	

The performance of the product identified above is in conformity with the set of declared performance/s.

This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

A handwritten signature in black ink, appearing to read 'Kevin O'Reilly', written over a horizontal line.

Kevin O'Reilly
Technical Director

Dated 18-04-2024