

# DECLARATION OF PERFORMANCE



## DoP-ITS.11204.2.5-UKCA



### (ITS.11204.2.5)

- Unique identification code of the product / type:-  
**ITS.11204 2-4 variable power Concealed Door Closer, with adjustable latch action, 110 degree maximum opening angle.**
- **Re-order Code allowing identification of the construction product as required under Article 11(4) of CPR:**  
11172, 11173, 11170, 11171, 12026, 12521, 12199
- Intended use:- On fire and smoke compartmentation doors (to fulfil the self-closing requirements of such doors)
- Manufacturer:- Rutland UK, Unit 4, Holmewood Business Park, Chesterfield Road, Chesterfield, S42 5US, UK
- System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V :- System 1
- Designated Standard:- EN 1154:1996 + A1:2002 / AC:2006
- Approved Body:- IFCC UK Conformity Assessment body No. 1720
- Certification of Conformity No.:- 1720-CPR-0188
- Declared Performance:-

Conditioning: Concealed Closer power size 2-4 with micro rail and adjustable latch action with 120 degree maximum opening angle

Essential Characteristics	Performance	Harmonised Technical Specification
<i>Self-closing (5.2.1 General)</i>		EN 1154:1996 + A1:2002 / AC:2006
5.2.2 Durability	500,000 test cycles	
5.2.3 Closing moment	Power size 2 - 4	
5.2.4 Opening moment	Power size 2 - 4	
5.2.5 Efficiency	Pass	
5.2.6 Closing time	Pass	
5.2.7 Angles of operation	Grade 3 for closing doors from 105 degrees	
5.2.8 Overload performance	Pass	
5.2.9 Temperature dependence	-15°C to +40°C	
5.2.10 Fluid leakage	Pass	
5.2.11 Damage	Pass	
5.2.12 Latch control	Pass	
5.2.13 Back check	NPD	
5.2.14 Delayed Closing	NPD	
5.2.15 Adjustable closing force	Pass	
5.2.16 Zero position	NPD	
5.2.18 Suitable for Fire/ Smoke	Grade 1	

# DECLARATION OF PERFORMANCE



<i>Durability of Self Closing</i>		EN 1154:1996 + A1:2002 / AC:2006
5.2.2 Durability	500,000 test cycles – Grade 8	
5.2.17.1 Corrosion resistance	High corrosion resistance - Grade 3 (96 hours)	
5.2.17.2 Corrosion resistance	Pass	
Dangerous Substances	Pass: the materials in the door closer do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations (1)	

The performance of the product identified above is in conformity with the set of declared performance/s.

This Declaration of Performance is issued, in accordance with Regulation (EU) No 305/2011 as it has effect in the United Kingdom in respect of Great Britain, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

Kevin O'Reilly - Technical Director  
At Rutland Trading Co Ltd  
Unit 4, Holmewood Business Park, Chesterfield Road, Chesterfield, S42 5US

on 10-03-2025